

**MITL's response on the Queries from bidders on Tender No: MITL/SBIA/2025-26/T-15**

Sr. No.	Reference to Tender Document	Suggestion/ Justification	MITL Response
<b>Bidder-1</b>			
1.	Vol-1, part-1 ITB, Clause no 2.3.3, page no.13 Definition of 'Similar works, or 'Similar project'	For technical qualification criteria mentioned only 33KV similar type of experience. As this is only labour rate contract we request you to allow similar type of work experience as 11KV/33KV.	Request accepted, Corrigendum-1 will be issued accordingly.
<b>Bidder-2</b>			
1.	General	Proper Cable size for Lubrizol India Ltd. Cable size mentioned as per price schedule.	For Lubrizol India Ltd Cable size as below: One (1) Ring of 300 Sq. mm & Second (2) Ring of 240 Sq.mm.
2.	General	Earthing Details for 33KV RMU	For each RMU 2 No. of maintenance free earthing comprising of electrode of 17.2 mm diameter Low Carbon Steel with 250-micron molecular copper bonded earthing rod of Length 3m along with Carbon based environment friendly back fill ground enhancing compound required to fill up the excavated earth with required quantity (min. 125kg) complete, and recording the results specification no. EA-MF