


Maharashtra Industrial Township Limited (MITL)
Design, Construction, Testing, Commissioning, Operation and
Maintenance of 60m wide Road along with all Utilities and Allied
Infrastructure Works at AURIC - Bidkin Industrial Area (BIA),
Sector B & C on EPC Basis

Request for Proposal cum Request for Qualification
Volume II - Technical Specifications
Part C - Wet Utilities
August 2026



This page is intentionally blank.

Table of Contents

1	Water Transmission and Distribution Network including Firefighting System.....	1
1.1	Scope	1
1.2	Background	3
1.3	Design Period for Various Components	5
1.4	Transmission Network	6
1.5	Surge Analysis.....	6
1.6	River/Stream/Channel crossings	6
1.7	Distribution Network.....	7
1.8	SCADA/ Automation	7
1.9	Excavation Depth	7
1.10	Residual Pressure	8
1.11	Laying	8
1.12	Bedding	9
1.13	Thrust blocks	9
1.14	Joints	10
1.15	Valves and Fittings	10
1.16	Bends	11
1.17	Tees.....	11
1.18	Reducers	11
1.19	Flanged HDPE Pipe Ends	11
1.20	Slip-On Flanges	11
1.21	Electro Fusion Tapping Saddle, Branch Saddle & Fittings	11
1.22	Back Filling and Tamping	13
1.23	Property Connections	14
1.24	Design Parameters for Distribution Network.....	14
1.25	List of Standards and Specifications.....	15
2	Recycle Water Supply Network.....	16
2.1	Background	17
2.2	Scope	17
2.3	Crossing of Transmission Lines and Distribution Network over Small River and Nallah	20
2.4	Distribution Network.....	20
2.5	SCADA/ Automation	21
2.6	Excavation Depth	21
2.7	Residual Pressure	21
2.8	Laying	21
2.9	Bedding	22
2.10	Thrust Blocks	23

2.11	Joints	23
2.12	Valves and Fittings	24
2.13	Back Filling and Tamping	24
2.14	Property Connections	25
2.15	Design Parameters for Distribution Network.....	25
2.16	List of Standards and Specifications.....	26
3	Stormwater Drainage.....	28
3.1	Scope	28
3.2	Catchments	29
3.3	Hydraulic & Hydrological analysis for estimation of the Highest Flood Level	30
3.4	Storm Frequency/ Return Period	30
3.5	Rainfall Intensity	30
3.6	Other Design Parameters	30
3.7	Design Methodology	31
3.8	Covered Lined Drain for Storm Water System	34
3.9	Drain Size, Depth and Type	35
3.10	List of Standards and Specifications.....	35
4	Industrial Wastewater and Domestic Sewage Collection System	37
4.1	Scope	37
4.2	Design Details for Industrial Wastewater and Domestic Sewage Collection System.....	38
4.3	Background	39
4.4	Estimated Generation of Industrial Wastewater and Domestic Sewage ...	41
4.5	Rate of Infiltration	42
4.6	Design Period	42
4.7	Peak Factor	42
4.8	Sewage Pumping Stations	43
4.9	Property Connections	45
4.10	Coefficient of Roughness	46
4.11	Design Capacity of Sewers.....	46
4.12	Minimum and Maximum Velocity in Sewer	46
4.13	Slope in Industrial Wastewater and Domestic Sewage Collection System	46
4.14	Bedding	47
4.15	Manhole Size, Depth, and Type	47
4.16	Spacing of Manholes	47
4.17	Cover Frame.....	48
4.18	Crossing of Sewer lines over Small River and Nallah	48
4.19	SCADA/ Automation	49
4.20	List of Applicable Codes and Standards.....	49

List of Tables

Table 1-1: Unit Water Demand	3
Table 1-2: Net Water demand for Sector B & C (BIA)	4
Table 1-3: Peak Factors for Contributory Population for Water Supply	5
Table 1-4: Tentative Details of Property Connections	14
Table 1-5: Design Parameters for Potable Water Distribution Network.....	14
Table 2-1: Details of Property Connections	25
Table 2-2: Design Parameters for Distribution Network	25
Table 3-1: Minimum Free Board	31
Table 3-2: Runoff Coefficients for Rational Formula (refer IRC SP 50 Table-6.1).....	34
Table 4-1: Design parameters of domestic sewerage & industrial effluent system	38
Table 4-2: Design parameters of Manholes.....	38
Table 4-3: Domestic Sewage / Industrial Effluent Generation	41
Table 4-5: Peak Factors for Contributory Population for Per Capita Sewage Flow.....	42
Table 4-6: Tentative Details of Property Connections	45
Table 4-7: Maximum and Minimum Velocity in Sewer.....	46
Table 4-8: Minimum Slopes	46
Table 4-9: Manhole Sizing	47
Table 4-10: Manhole Cover Details	48

Disclaimer

This Tender is not an Agreement and is neither an offer nor an invitation by the Employer to the prospective Bidders or any other person. The information contained in this tender document or subsequently provided to Bidder(s), whether verbally or in documentary or any other form by or on behalf of the Employer or any of its employees or advisors, is provided to Bidder(s) on the terms and conditions set out in this tender and such other terms and conditions subject to which such information is provided.

The purpose of this tender is to provide interested parties with information that may be useful to them in making their financial offers (BIDs) pursuant to this tender. This tender includes statements, which reflect various assumptions and assessments arrived at by The Employer in relation to the Project. Such assumptions, assessments and statements do not purport to contain all the information that each Bidder may require. This tender may not be appropriate for all persons, and it is not possible for the Employer, its employees or advisors to consider the objectives, financial situation and particular needs of each party who reads or uses this tender. The assumptions, assessments, statements and information contained in the Bidding Documents, especially the Preliminary Design details/ information, may not be complete, accurate, adequate or correct. Each Bidder should, therefore, conduct its own investigations and analysis and should check the accuracy, adequacy, correctness, reliability and completeness of the assumptions, assessments, statements and information contained in this tender and obtain independent advice from appropriate sources.

Information provided in this tender to the Bidder(s) is on a wide range of matters, some of which may depend upon interpretation of law. The information given is not intended to be an exhaustive account of statutory requirements and should not be regarded as a complete or authoritative statement of law. The Employer accepts no responsibility for the accuracy or otherwise of any interpretation or opinion on law expressed herein.

The Employer, its employees and advisors make no representation or warranty and shall have no liability to any person, including any Applicant or Bidder under any law, statute, rules or regulations or tort, principles of restitution or unjust enrichment or otherwise for any loss, damages, cost or expense which may arise from or be incurred or suffered on account of anything contained in this tender or otherwise, including the accuracy, adequacy, correctness, completeness or reliability of the tender and any assessment, assumption, statement or information contained therein or deemed to form part of this tender or arising in any way for participation in this Bidding Process.

The Employer also accepts no liability of any nature whether resulting from negligence or otherwise howsoever caused arising from reliance of any Bidder upon the statements contained in this tender.

The Employer may in its absolute discretion, but without being under any obligation to do so, update, amend or supplement the information, assessment or assumptions contained in this tender. The issue of this tender does not imply that the Employer is bound to select a Bidder or Contractor, as the case may be, for the Project and The Employer reserves the right to reject all or any of the Bidders or Bids without assigning any reason whatsoever.

The Bidder shall bear all its costs associated with or relating to the preparation and submission of its BID including but not limited to preparation, copying, postage, delivery fees, expenses associated with any demonstrations or presentations which may be required by The Employer or any other costs incurred in connection with or relating to its BID. All such costs and expenses shall remain with the Bidder and The Employer shall not be liable in any manner whatsoever for the same or for any other costs or other expenses incurred by a Bidder in preparation or submission of the BID, regardless of the conduct or outcome of the Bidding Process.

Nothing in this tender shall constitute the basis of a contract which may be concluded in relation to the Project nor shall such documentation/information be used in construing any such contract. Each Bidder must rely on the terms and conditions contained in any contract, when, and if, finally executed, subject to such limitations and restrictions which may be specified in such contract.

The Bidders are prohibited from any form of collusion or arrangement in an attempt to influence the selection and award process of the Bid. Giving or offering of any gift, bribe or inducement or any attempt to any such act on behalf of the Bidder towards any officer/employee of Employer or to any other person in apposition to influence the decision of the Employer for showing any favour in relation to this tender or any other contract, shall render the Bidder to such liability/penalty as the Employer may deem proper, including but not limited to rejection of the Bid of the Bidder and forfeiture of its Bid Security.

Laws of the Republic of India are applicable to this tender.

Each Bidder's procurement of this tender constitutes its agreement to, and acceptance of, the terms set forth in this Disclaimer. By acceptance of this tender, the recipient agrees that this tender and any information herewith supersedes documents(s) or earlier information, if any, in relation to the subject matter hereto.

1 Water Transmission and Distribution Network including Firefighting System

1.1 Scope

The potable water supply scheme for the Bidkin Industrial Area has been designed to cater to the Priority I area through a piped distribution network, utilizing surface water from Jayakwadi Dam as the source. The overall scheme includes the water distribution system and service connections.

MITL shall be responsible for the abstraction of raw water from the source (Jayakwadi Dam) through a jack well and for pumping/conveying it to the inlet chamber of the Water Treatment Plant (WTP) for BIA. The subsequent works, classified under Priority 1, comprise the distribution network and service connections to all plots/abutting roads.

The scope of the present contract shall comprise design, supply, installation, testing, commissioning, operation, and maintenance of the Priority 1 works.

The Contractor shall undertake surge analysis for the entire potable water distribution network and shall provide surge protection measures/equipment, wherever necessary, as per the approved design.

The scope of work shall include but not be limited to the following:

- a) Detailed design of the distribution system and service connections.
- b) Submission of design calculations, plans, 2D models and drawings.
- c) A branch connection is provided for future supply. The branch connection from the 60 m ROW pipeline is terminated at 50 m with an isolation valve and valve chamber, intended for future tie-in.
- d) Preparation of L section.
- e) Construction of a Potable Water Network as per the approved design and plans
- f) Supply and installation of Flow meters, Level sensors, Pressure sensors, and Valves as per the approved design.
- g) Supply and installation of Smart water meters to consumers of all types.
- h) Supply, Construction, Installation, Testing, Commissioning and O&M of the Potable Water Supply System. The contractor has to manage the water supply distribution network such that the distribution losses should not exceed 5%. The measurement shall be with reference to the flowmeter at the inlet of the Service Reservoir and the Inlet at the consumer meter.

The contractor shall design and construct the potable water supply system on a continuous running basis, along with the installation of valves, scour valves, air release valves, thrust blocks etc. as required. All valves shall be electrically actuated except scour and air release valves.

The Contractor shall furnish all required tools, plant, instruments, materials including water, electricity, labour, consumables, etc., any and everything necessary for the

construction of the works, whether or not such items are specifically stated elsewhere in this document.

The system shall be designed for efficient operations and taking the concept of a District Metering Area (DMA) with each DMA being isolated with valves and flow measured with a full-bore electromagnetic flow meter to each DMA.

In general, this work shall include designing, providing, laying, jointing and testing all pipes and specials/fittings, DI/HDPE pipe and specials/fittings, inlet connection, Valves, etc.

SI	Description of Item	Minimum Requirement
1	Potable Water Transmission Line for Priority 1 including the connections for other adjacent area	DI K9
2	Potable Water Distribution Network	
a	HDPE Pipe sizes PE 100 PN-10	110 mm to 280 mm
b	DI Pipe sizes- K9	300 mm and above
c	Sluice Valves	Motorized actuator
d	Air Release Valves	Automatic
e	Scour Valve	Manual
3	Potable Water Management System (web-based and app-based)	Potable Water Management system to be integrated with its respective SCADA. The contractor shall be responsible for coordination related to the interfacing with the ICCC system (by others). Any control system under the contractor's scope shall be fed with power from UPS, supplied by the contractor. A separate operation room of 50 sq.m will be provided.
4	Flow Meters (all types)	Battery-operated electromagnetic type/power operated with min 8 hours UPS backup having integration with Potable Water management system. Each flow meter shall have appropriate RTU-compatible GSM and OFC connectivity with respective SCADA (by contractor) for control and monitoring. However, Contractor has to ensure its interface with ICCC (by others) for monitoring only through their utility SCADA.
5	Service Water Connection	Minimum 32 mm
6	Service Water Meters	Battery-operated, Ultrasonic with 2 GSM SIMs/IoT enabled and

SI	Description of Item	Minimum Requirement
		compatible with the Potable Water Management System.
7	Firefighting Water Hydrants at every junction and designated locations.	Two-way brass hydrants with Battery-operated, Ultrasonic with 2 GSM SIMs and compatible with the Potable Water Management System.
8	The preliminary drawings shall be prepared to ensure that the water requirements of all plots located along the existing 60 m road, as well as the plots proposed along the future road, are adequately met through the water-supply pipeline network included within the current 60 m road execution scope. While carrying out the detailed design, the contractor shall consider the present and projected future water demand of all such plots and accordingly design the complete water-supply network within the current 60 m road corridor, including adequate capacity and suitable provisions for future connectivity.	

1.2 Background

The Service Reservoir shall be implemented in another Phase of the BIA, which is proposed to be located within the WTP premises. The transmission main will be laid from the clear water pump house up to the inlet valve chamber of the Service Reservoir under a separate contract. The distribution network shall start from the Service Reservoir.

Per Capita Water Supply

Water demand for Sector B & C has been estimated based on the unit demand norms adopted from the CPHEEO manual on Water Supply & Treatment & National Building Code and considering the land use master plan and projected population. The unit demand for different land uses shall be referred to in Table 1-1 below.

Table 1-1: Unit Water Demand

S. No.	Category	Unit	Water Demand	Potable Water	Non-potable / Recycled Water
1.	Pharma industries	KL/ha/day	72.73	36.365	36.365
2.	Engineering industries	KL/ha/day	25	10	15
3.	Food industries	KL/ha/day	70.3	35.15	35.15
4.	Residential	LPCD	135	90	45
5.	Commercial	LPCD	45	25	20
6.	Hotels - 2-star or 3-star	l/key/day	180	120	60
7.	Nursing home, child welfare, maternity centre (25-30 beds) and Polyclinic	l/bed/ day	340	230	110
8.	Multi-specialty Hospital & General Hospital	l/bed/ day	450	300	150
9.	Primary/ Secondary School and School for Physically	LPCD	45	25	20

S. No.	Category	Unit	Water Demand	Potable Water	Non-potable / Recycled Water
	Challenged				
10.	Community rooms, recreational clubs, religious facilities	LPCD	45	25	20
11.	Fire Station	LPCD	45	25	20
12.	Malls (Visitor)	LPCD	15	5	10
13.	Open Space/Green area	l/m ² /day	3.5	-	3.5
14.	Roadside Plantation	l/m ² /day	3.5	-	3.5

Figures exclude “Unaccounted for Water (UFW)” which should be limited to 10%.

1.2.1 Firefighting requirements

As per IS 9668, water for firefighting shall be provided at the scale of 1800 lpm for every 50,000 population or part thereof for towns up to 3 lacs population and an additional 1800 lpm for every 1 lac population of more than 3 lacs. The fire scenario will be accordingly modelled and evaluated, adding potable water demands. IS 9668 stipulates that the provision of 2 hrs for firefighting should be made.

The fire hydrants will be proposed on a potable water network with two-way type fire hydrants. The hydrants will be spaced as per IS 13039.

For providing the fire-fighting storage, higher of provision as recommended by CPHEEO and IS 9668 should be adopted. Fire demand shall be considered in the potable water distribution network design.

The provision of water required for firefighting shall be considered in the design of the potable water Service Reservoir. The minimum pressure of 17m to 21 m should be maintained within the potable water network on which the fire hydrants are proposed.

As per IS 908 (Specification for Fire Hydrant, Stand Post Type) The hydrant shall consist of two sluice valves with road surface boxes, a bend, a flange riser and a stand post column fitted with 63-mm male coupling(s).

The entire area (industrial, residential, and commercial) shall be developed in accordance with the National Building Code (NBC)/ International fire norms. The industries shall be required to implement fire protection systems as per the relevant hazard category.

1.2.2 Water Demand

Based on the above parameters, the tentative water demands for different land uses are as described hereunder. The breakup of total water demand is provided in the table below:

Table 1-2: Net Water demand for Sector B & C (BIA)

Land use	SECTOR-B		SECTOR-C		Water Demand	
	Potable water demand (MLD)	Non-potable /Recycled water demand (MLD)	Potable water demand (MLD)	Non-potable /Recycled water demand (MLD)	Potable water demand (MLD)	Non-potable water demand (MLD)
Pharma industries	1.38	0.92	0.54	0.36	1.92	1.28
Industries	9.58	6.39	3.77	2.51	13.35	8.9
Residential	11.39	5.70	10.66	5.33	22.05	11.03
Commercial	0.32	0.16	0.08	0.04	0.4	0.2
Amenity	1.81	0.90	0.79	0.39	2.6	1.29
Open space / Green area	-	3.12	-	1.25	-	4.37
Road	-	0.42	-	0.26	-	0.68
Total	24.47	17.60	15.84	10.15	40.31	27.75

Figures exclude “Unaccounted for Water (UFW)” which should be limited to 10%.

1.2.3 Peak Factors

As far as the design of the distribution system is concerned, it is the hourly variation in consumption that matters. The fluctuations in consumption are accounted for, by considering the peak rate of consumption as the rate of flow in the design of the distribution system.

The following peak factors shall be adopted as recommended in the CPHEEO manual for Water Supply and Treatment.

Table 1-3: Peak Factors for Contributory Population for Water Supply

Contributory Area	Peak Factor
For Urban Area	2.5
For Rural Area	3

The peak factor shall depend upon the contributory population on respective lines of different zones as shall be proposed during designing of distribution network.

1.3 Design Period for Various Components

Water supply projects are designed to meet the future requirements of a stipulated design period. This period, with regard to certain components of the project, depends on their useful life or the facility for carrying out extensions whenever required, so that expenditure far ahead of its utilization is avoided and capital expenditure incurred on the project does not remain idle due to underutilization of these facilities. For designing such systems, a 30-year project period is recommended. The design period normally considered for various components is as under:

- a) Civil Structures: 30 years
- b) Pumping Mains: 30 years
- c) Mechanical and Electrical Components: 15 years

- d) Distribution System: 30 years

1.4 Transmission Network

The transmission mains shall be designed on a continuous pressurized water supply. The work of the potable water transmission main from the clear water pump house up to the inlet valve chamber (including its construction) of the Service Reservoir will be executed by another contractor. The transmission main from the inlet valve chamber up to the terminal point into the Service Reservoir is included in the scope of this contract.

1.5 Surge Analysis

Surge analysis for the distribution system, along with the design and provision of the required surge protection devices, shall be the responsibility of the Contractor. The surge control systems shall be designed so as to ensure that:

- a) The maximum residual surge shall be restricted to 10% of the maximum surge which would have developed without the surge control devices at any point in the pipeline or 10% of the design pump head, whichever is more; and
- b) The vacuum pressure developed in the pipeline at any place shall be restricted to -3 m (minus 3 meters).
- c) The surge protection system provides adequate protection against damage to the valves, pipe delivery systems and pumps.

1.6 River/Stream/Channel crossings

Suitable pipe bridges shall be provided at the locations where the proposed potable water supply main will cross river/ stream/nallah. The bottom level of the pipe shall be kept above the maximum water level in the water course. Final Locations of crossing shall be verified on site and design to be done by the contractor.

At a river where there is a road crossing (bridge/ viaducts) for vehicles or passengers, the span supports for the pipeline shall match with the supports of the bridge/ viaduct. For other culvert, stream and nallah crossings, the pipe bridges shall be designed with a maximum span of 5m. The pipe supports of the pipe bridge shall be designed and constructed in accordance with approved standards. The contractor shall design and obtain approval on the final detailed arrangements from the Engineer-in-Charge before work.

In case the pipeline is passing through the bed level of the stream/nallah, the pipe shall be completely encased in the concrete of minimum M15 grade. Before placing concrete, the pipes shall be supported near each joint with a padding of compressive material on a pre-cast concrete block. Concrete shall not be placed until the pipes have been joined, inspected, and passed hydraulic testing.

The concrete shall be placed to ensure full contact with the pipe barrel throughout its length. Necessary reinforcement steel shall be provided as per the approved design and site conditions. The concrete shall be made discontinuous at flexible pipe joints by a diaphragm of fibre board or other compressible material of at least 20 mm thickness

extending for the full area of the surround. The concrete encasement shall cover the pipeline on all sides by a minimum of 100 mm on each side.

1.7 Distribution Network

The distribution network shall be designed on a continuous pressurized water supply. Hazen William's formula will be used for the calculation of velocities and head losses. The water distribution network shall be mostly a closed network system so that uniform pressure is maintained at ferrule connections for each consumer. The Hazen-Williams formula is expressed as under:

$$S = hf / L = 10.67 [(Q / C)^{1.85}] [1 / (d^{4.87})]$$

Where,

S: Hydraulic slope

hf: head loss in meters (water) over the length of the pipe

L: length of pipe in meters

Q: volumetric flow rate, m³/s (cubic meters per second)

C: pipe roughness coefficient

d: inside pipe diameter, m (meters)

The following considerations shall be considered while designing the network:

Minimum velocity = 0.6 m/s

Maximum velocity = 3.0 m/s

1.8 SCADA/ Automation

The contractor is to ensure the compatibility and seamless transmission of the data from the Potable Water Management System to the Integrated Command and Control System to be installed by the Master ICT System Integrator.

The sluice / butterfly valves for all pipelines shall have electrically operated actuators with appropriate RTU-compatible GSM and OFC connectivity with respective SCADA (by contractor) for control and monitoring.

However, Contractor has to ensure its interface with ICCC (by others) through their utility SCADA for monitoring only.

The contractor shall be responsible for coordination related to the interfacing with the ICCC system (by others).

Any control system under the contractor's scope shall be fed with power from UPS, to be supplied by the contractor.

1.9 Excavation Depth

All water supply pipes shall be laid below ground with a minimum clear cover of 1.2m above the crown of the pipes. No cover less than the above is acceptable.

The contractor also needs to check and design an anchoring arrangement to mitigate the uplift of pipes due to the water table in the project area.

1.10 Residual Pressure

The potable water supply distribution system shall be designed to achieve a minimum residual pressure of 17-21 m at the ferrule point of each service connection.

To meet the fire demand, a minimum residual pressure at the fire hydrant locations shall be considered as 17-21m.

1.11 Laying

The pipes shall be lowered into the trench by means of suitable pulley blocks, sheer legs chains ropes etc. In no case, the pipes shall be rolled and dropped into the trench. One end of each rope may be tied to a wooden or steel peg driven into the ground and the other end held by men which when slowly released will lower the pipe into the trench. After lowering, the pipes shall be arranged so that the spigot of one pipe is carefully centred into the socket of the next pipe, and pushed to the full distance that it can go. The pipeline shall be laid to the levels required. Specials shall also be laid in their proper position.

Where so directed, the pipes and specials may be laid on masonry or concrete pillars. The pipe laid on the level ground shall be laid with a socket facing the direction of the flow of water.

The pipes shall rest continuously on the bottom of the trench. The pipes shall not rest on lumps of earth or on the joints. Four-meter-long wooden templates may be used to check the level of the bed. Clearance of approximately 100 mm in depth and width equal to the length of the collar plus 30mm on both sides shall be provided at the joint which shall be refilled from sides after the joint is made.

In unstable soils, such as soft soils and dry lumpy soils it shall be checked whether the soils can support the pipelines and if required suitable special foundation shall be provided.

Some clayey soils (for example black cotton soil) are drastically affected by extremes of saturation and dryness. In changing from saturated to a dry condition, these soils are subjected to extraordinary shrinkage which is usually seen in the form of wide and deep cracks in the earth's surface and may result in damage to underground structures, including pipe materials. The clay forms a tight gripping bond with the pipe, subjecting it to excessive stresses as the clay shrinks. It is recommended that in such cases an envelope of a minimum of 100 mm of tamped sand shall be made around the pipeline to avoid any bonding.

In places where rock is encountered, a cushion of fine earth or sand shall be provided for a depth of 150 mm by excavating extra depth of the trench, if necessary, and the pipes laid over the cushion. Where the gradient of the bed slopes is more than 30 degrees it may be necessary to anchor a few pipes against sliding downwards.

1.12 Bedding

The class of bedding have been designed considering the required external loading conditions, geotechnical requirements such as subsoil and bearing capacity of soil encountered in the respective water line, type, class, and material of pipe used for the laying purposes as per the CPHEEO manual. Fine sand bedding 200mm thick shall be provided for HDPE Pipes.

Where DI pipes are to be bedded directly on the bottom of the trench, it is to be trimmed and levelled to permit even bedding of the pipeline and should be free from all extraneous matter which may damage the pipe or the pipe coating. Additional excavation is made at the joints of the pipes so that the water main is supported along its entire length. Where excavation is through rocks or boulders, the pipeline is bedded on concrete bedding or on at least 150 mm of fine-grained material, or other means are used to protect the pipe and its coating.

For MS pipes the bottom of the trench is properly trimmed to permit even bedding of the pipeline. For pipes larger than 1200 mm diameter in earth and murrum the curvature of the bottom of the trench matches the curvature of the pipe as far as possible, subtending an angle of about 120° at the centre of the pipe. Where rock or boulders are encountered, the trench is trimmed to a depth of at least 100 mm below the level at which the bottom of the barrel of the pipe is to be laid and filled to a like depth with lean cement concrete or with the non-compressible material like sand of adequate depth to give the curved seating.

1.13 Thrust blocks

Thrust blocks are required to transfer the resulting hydraulic thrust from the fitting of the pipe onto a larger load-bearing soil section.

Thrust blocks shall be installed wherever there is a change in the direction/size of the pipeline or the pressure line diagram, or when the pipeline ends at a dead end. If necessary, thrust blocks may be constructed at valves also.

Thrust blocks shall be constructed considering the pipe size, water pressure, type of fitting, gravity component when laid on slopes and the type of soil.

When a fitting is used to make a vertical bend, it shall be anchored to a concrete thrust block designed to have enough weight to resist the upward and outward thrust. Similarly at joints, deflected in a vertical plane, it shall be ensured that the weight of the pipe, the water in the pipe and the weight of the soil over the pipe provide resistance to upward movement. If it is not enough, ballast or concrete shall be placed around the pipe in sufficient weight to counteract the thrust.

When the line is under pressure there is an outward thrust at each coupling. Good soil, properly tamped is usually sufficient to hold pipe from side movement. However, if soft soil conditions are encountered, it may be necessary to provide side thrust blocks of other means of anchoring. In such cases, only the pipe on each side of the deflected coupling shall be anchored without restricting the coupling.

Pipes on slopes need to be anchored only when there is a possibility of the backfill around the pipe sloping down the hill and carrying the pipe with it. Generally, for slopes up to 30 degrees good well-drained soil carefully tamped in layers of 100 mm under and over the pipe, right up to the top of the trench will not require anchoring.

1.14 Joints

A Joint is a connection between the ends of pipes in which a gasket is used to affect a seal.

Ductile Iron pipes comprise of the following joints:

- a) Socket and Spigot Push-on Joint
- b) Flanged Joint
- c) Flexible Joints and Interconnection and
- d) Restrained Joints

Push-on flexible joints shall be provided for pipe-to-pipe connection as per IS 8329. Wherever, flange joints are required e.g., at terminal points, valves, over-ground, and underground pipe connections etc., welded-on flanges shall be used.

Double-chambered restrained joints need to be designed in accordance with ISO 10804:2018. The permissible angular deflection will be as declared by the manufacturer. The Performance Type Test of this Joint in line with ISO 10804/EN545 has to be established by the manufacturer by getting it witnessed by a NABCB (National Accreditation Board for Certification Bodies), or IAF (International Accreditation Forum) or EA (European Cooperation for Accreditation) accredited institution/certification agency.

1.15 Valves and Fittings

For the operation and maintenance of the transmission and distribution system, minimum numbers of valves are necessary. The transmission and distribution mains shall be provided with the following appurtenances and specials as per the following criteria.

1.15.1 Sluice Valve

Resilient seated sluice valves of standard make as per IS 14846 shall be proposed at different locations as per requirements to isolate a portion for maintenance.

1.15.2 Non-Return Valve

Non-return valves of standard make as per IS 5312 shall be proposed at different locations as per requirements to prevent any backflow.

1.15.3 Pressure Reducing Valve

Pressure-reducing valves with pressure-sustaining overrides have been provided to reduce the pressure difference between the locations of the same zones. It will also prevent the reduction of pressure beyond a minimum defined value.

1.15.4 Auto Release Valve

Automatic release valves with EPDM of standard make shall be proposed at suitable locations in the rising mains and distribution network to protect the line from both upsurges and down surges. The valve diameter shall be as per design requirements and guidelines.

1.15.5 Scour Valve

Scour valves of standard make have been proposed to be installed in the rising mains and distribution system at lower points in the line to drain silt and water from the line whenever required.

All the valves shall be enclosed in valve chambers with cover.

All HDPE fittings/ specials shall be of minimum PN 10 or above Pressure class, fabricated in accordance with IS: 8360 (Part I & III). PE Injection moulded fittings shall be as per IS: 8008 (Part I to IX). All fittings/ specials shall be fabricated or moulded at the factory only. No fabrication or moulding will be allowed at the site unless specifically permitted by the Engineer-in-Charge. Fittings will be welded onto the pipes or other fittings by use of Electrofusion process.

1.16 Bends

HDPE bends shall be plain square ended conforming to IS: 8360 Part I & III Specifications. Bends shall be moulded.

1.17 Tees

HDPE Tees shall be plain square ended conforming to IS: 8360 Part I & II Specifications. Tees may be equal tees or reduced take-off tees. Tees shall be moulded.

1.18 Reducers

HDPE Reducers shall be plain square ended conforming to IS: 8008 Part I & VII Specifications. The reducer must be moulded.

1.19 Flanged HDPE Pipe Ends

HDPE Stub ends shall be square-ended conforming to IS: 8008 Part I & VI Specifications. Stub ends will be welded on the pipe. The flange will be of slip-on flange type as described below.

1.20 Slip-On Flanges

Slip-on flanges shall be metallic flanges covered by epoxy coating or plastic powder coating. Slip-on-flanges shall be conforming to standard mating relevant flange of valves, pipes etc. The nominal pressure rating of flanges will be PN10.

1.21 Electro Fusion Tapping Saddle, Branch Saddle & Fittings

- a) All the Electrofusion fittings should be manufactured with top-quality virgin pre-compounded PE 100 resin which should be compatible with the distribution mains.

- b) The products shall comply with the requirements of EN 12201-3, EN 1555- 3 or ISO 8085-3.
- c) All the fittings shall be of SDR 11 rating.
- d) The fittings shall have approval from any agencies like CIPET etc.
- e) All the products shall be manufactured by injection moulding using virgin compounded PE 100 polymer having a melt flow rate between 0.2- 1.4 grams/10 minutes and shall be compatible for fusing on PE 100 distribution mains manufactured according to the relevant national or international standards. The polymer used should comply with the requirements of EN 12201 -1.
- f) Process voltage of all saddles must not exceed a maximum of 40 volts.
- g) The heating elements should be designed for fusion at any ambient temperature between -5 to +40 degrees centigrade.
- h) The heating coils contained in each individual saddle should be so designed that only one complete process cycle is necessary to fully electro fuse the fitting to the adjoining pipe or pipeline component as applicable. The heating coils shall be terminated at terminal pins of 4.0- or 4.7-millimetre diameter.
- i) No heating element shall be exposed, and all coils are to be an integral part of the body of the fitting.
- j) The EF tapping/ branch saddles should be fixed by a fixation device and shall be achieved by an external or integral clamping device.
- k) The cutter should be designed in such a way that the cut coupon is not allowed to fall into the pipeline and is retained inside the body of the cutter.
- l) A limited path style fusion indicator acting for each fusion zone as visual recognition of the completed fusion cycle should be incorporated into the body of each fitting near the terminals. The fusion indicators should not allow the escape of the molten polymer through them during or after the fusion process.
- m) All the sockets in the electro-fusion fittings should include a method of tapping controlling the pipe penetration (pipe positioner /stopper).
- n) All the electro-fusion products should be individually packed in transparent protective bags to allow easy identification without opening the bag and must clearly indicate their contents.
- o) The brand name, size, raw material grade, SDR rating and batch identification are to be embedded as part of the injection moulding process. Each fitting should also be supplied with a Data Card or stickers with the appropriate barcode as well as manual setting information for data transfer purposes.
- p) Installation and Fusion Jointing: The fusion jointing process is to be carried out as per the procedure outlined in the DVS2202 standard, if not available equivalent standards are acceptable to the employer.

- q) A protocol for each fusion joint to be printed to ensure the joint process carried out is error-free. The electro-fusion machine shall have the facility to record & make print for each joint.
- r) The precautions & measures mentioned by electrofusion fittings/ machine manufacturers should be taken up rigorously while making the joints in the field.
- s) The jointing procedures shall be performed with the required accessories and tools as recommended by the fittings manufacturer.
- t) The related pipe jointing accessories such as rotary pipe cutter, Universal clamping tools, Pipe cleaners, and Pipe peelers supplied by the same electro-fusion fitting/ machine supplier shall be used to ensure perfect jointing.
- u) The usage of tapping tools such as tapping keys, supplied by the same electro-fusion fitting/ machine supplier must be used to ensure perfect tapping of main lines.
- v) The piping system will be tested as per the guidelines given by ISO standards. The guideline shall be furnished by the supplier of electro-fusion fittings, tools, and machines.

1.22 Back Filling and Tamping

Backfilling shall follow pipe installation as closely as possible to protect the pipe from falling boulders, eliminating the possibility of pipe lift due to flooding of the open trench and shifting the pipe out of line by caved-in soil.

The soil under the pipe and coupling shall be solidly tamped to provide firm and continuous support for the pipeline. Tamping shall be done either by tamping bars or by using water to consolidate the backfill materials. The minimum MDD of compacted soil shall not be less than 95%.

The initial backfill material used shall be free of large stones and dry lumps. In stony areas, the material for initial backfill can be shaved from the sides of the trenches. In bogs and marshes, the excavated material is usually little more than vegetable matter and this should not be used for bedding purposes. In such cases, gravel or crushed stone shall be hauled in.

The initial backfill shall be placed evenly in a layer of about 100 mm thick. This shall be properly consolidated, and this shall be continued till there is a cushion of at least 300 mm of cover over the pipe.

If it is desired to observe the joint or coupling during the testing of mains, they shall be left exposed. Sufficient backfill shall be placed on the pipe to resist the movement due to pressure while testing.

Balance of the backfill need not be so carefully selected as the initial material. However, care shall be taken to avoid backfilling with large stones which might damage the pipe when spaded into the trench.

Pipes in trenches on a slope shall have extra attention to make certain that the newly placed backfill will not become a blind drain in effect because until back fill becomes

completely consolidated there is a tendency for ground or surface water to move along this looser soil resulting in a loss of support to the pipe. In such cases, the backfill shall be stamped with extra care and the tamping continued in 100 mm layers right up to the ground level.

1.23 Property Connections

Service pipes should be laid up to plot boundaries in the Project area and end capped. The service pipe details are as defined below:

Table 1-4: Tentative Details of Property Connections

S.No.	Description	Value
1	Pipe and accessories	Service connections of required size as per water demand (Minimum 32 mm) including supply and fixing of ferrules, electro fusion saddle, clamps, rubber sheets, tapping, compression fittings etc, complete.
2	Pipe Material	HDPE
3	Number of property connections and water meters	96

1.24 Design Parameters for Distribution Network

Table 1-5: Design Parameters for Potable Water Distribution Network

SI	Design Parameter	Value
1	Minimum residual pressure at Consumer connection (unless otherwise specified by Employer/ Employer's Engineer)	17-21m
2	Peak factor	For Residential as per CPHEEO; For industrial to be decided as per industrial process. (minimum 1.5m)
3	Losses as Unaccounted for water (UFW) to be considered for designing	3% Treatment loss, 2% Pumping for Raw Water Transmission loss and Clear water transmission & distribution loss shall be restricted to 10%
4	Bedding	Bedding for HDPE / DI pipes shall be as per relevant IS codes
5	Clear cover over pipe	The water supply pipeline shall be laid with a minimum cover of 1.2m over the pipe crown.
6	Basis of supply to consumers	Continuous pressurized
7	Maximum Unit head loss in the pipe	10m/KM
8	Hazen William Coefficient	As per CPHEEO Manual
9	Pipe Material	HDPE minimum 110 mm up to 280mm HDPE (PE-100); PN 10 Size 300mm and above: DI-K9

1.25 List of Standards and Specifications

Detailed specifications for the water supply system have been presented in section 12.7. Key standards have been listed below.

- a) CPHEEO Manual for Water Supply & Treatment Systems, 2024
- b) SP 7 (2016): National Building Code of India, 2026
- c) Urban and Regional Development Plans Formulation and Implementation Guidelines, 2014
- d) SP-35: Handbook on Water Supply, Plumbing & Drainage, 1987
- e) Manual on norms and standards for environment clearance of large construction projects, MoEF
- f) IS 1172: Code of Basic requirements for water supply, drainage and sanitation
- g) IS 8329: Centrifugally Cast (spun) Ductile Iron Pressure Pipes for Water, Gas and Sewage — Specification
- h) IS 12288: Code of practice for laying of ductile iron pipes
- i) IS 9523: Ductile iron fittings for pressure pipes for water, gas and sewerage
- j) IS 4984: High Density Polyethylene Pipes for Water Supply
- k) Sluice valves shall be of Class I type with cap conforming to IS 780, it shall be provided with false spindle.
- l) The road surface box shall conform to IS 3950.
- m) Duck foot bend shall conform to IS 1538 heavy duty type.
- n) The flange riser shall conform to IS 7181. The length of the pipe shall be as required.
- o) Stand post column shall be of cast iron, cast in one piece conforming to Grade 20 of IS 210
- p) IS 13039: External hydrant systems-Provision and maintenance-code of practice
- q) Each hydrant shall be subject to hydrostatic test and shall prove perfectly watertight under a hydraulic pressure as per the IS 13039

2 Recycle Water Supply Network

High-quality treated water termed 'Recycle Water' will be produced from domestic sewage and industrial wastewater at the Sewage Treatment Plant (STP) and Common effluent treatment plant (CETP), respectively, which will be designed, supplied, installed, operated and maintained by the contractor as per the contract.

This Recycle Water will be used to meet the non-potable or non-drinking water demand from the residential, commercial, institutional, and industrial areas. Also, the water demand for horticulture/landscaping and a part of the process water demand of industrial areas will be met through this water.

The contractor will be responsible for the design, supply, installation, testing, commissioning, operation, and maintenance of a entire Recycle water distribution system. The scope includes a Recycle Water distribution system and a service connection to the plots.

The implementation limit will start from the outlet valve at the pump discharge of the Recycle Clear Water Reservoir (Re-CWR) up to the service connection points outside the plots in the Project area.

Recycle Clear Water Reservoir (Re-CWR), along with the Pump House to transfer water to the Recycle Water Service Reservoir (Re-SR), will be included in the scope of other Contractors. The Recycle Water Service Reservoir (Re-SR) will be in the scope of EPC Package A

The contractor scope shall include surge analysis for the complete Recycle water network and shall provide surge protection equipment wherever necessary. The Centre-to-centre distance of the riser connection to be considered for recycled water pipe along the green zone/area shall be as per the landscape design requirement and will be finalised during detailed design in consultation with the Employer's Engineer.

SI	Description of Item	Minimum Requirement
2	Recycle Water Transmission Line	DI K9
3	Recycle Water Distribution Network	As per the approved design
a	HDPE Pipe sizes PE-100 PN-10	110 mm to 280 mm
b	DI Pipe sizes	DI K9 for 300 mm and above
c	Sluice Valves	Motorized actuator
d	Air Release Valves	Automatic
e	Scour Valve	Manual
4	Recycle Water Management System (web-based and app-based)	Recycle Water SCADA which can be integrated with ICC. It should be capable of controlling and monitoring the flows through valves, real-time data collection and display of all water meters, flow meters, water level sensors, pressure sensors capability of report generation and alerts It is to be accommodated in the same room as that for the Potable Water Management System.

SI	Description of Item	Minimum Requirement
5	District Metering Area (DMA)	500-3000 HSC for plain area, 300-1500 HSC for Hilly Area
6	Flow Meters (all types)	Battery-operated electromagnetic type/power operated with min 8 hours UPS backup, having integration with the Potable Water management system.
7	Service Water Connection	For 96 plot connections with a minimum 32 mm diameter. Minimum 100 Nos. of tap-off points as required for the Landscape package (by other contractors). Tap-off points for irrigation of avenue plantation in ROW as per the Contractor's scope of work and design.
8	Service Water Meters	Battery-operated, Ultrasonic with 2 GSM SIMs and compatible with the Recycle Water Management System.
9	The preliminary drawings shall be prepared to ensure that the water requirements of all plots located along the existing 60 m road, as well as the plots proposed along the future road, are adequately met through the water-supply pipeline network included within the current 60 m road execution scope. While carrying out the detailed design, the contractor shall consider the present and projected future water demand of all such plots and accordingly design the complete water-supply network within the current 60 m road corridor, including adequate capacity and suitable provisions for future connectivity.	

2.1 Background

The STP and CETP will be co-located. The Recycle Water from both these facilities shall be pumped to a common reservoir. It is proposed to pump the treated effluent to a Recycle Water Service Reservoir (Re-SR) which is planned near to Service Reservoir (SR) for potable water. Recycle water shall be supplied from this recycle water storage facility.

The design period to be considered for various components is as under:

- a) Civil Structures: 30 years
- b) Pumping Mains: 30 years
- c) Mechanical and Electrical Components: 15 years
- d) Distribution System: 30 years

2.2 Scope

The Recycle Water Production and Distribution System shall be as follows:

- a) Recycle Water Distribution network and Recycle Water Service connections to all plots in Priority 1 for BIA.

The scope under the present contract will include design, supply, installation, testing, commissioning, operation, and maintenance of the recycled water distribution system.

The Recycled Water Service Reservoir shall be designed to take care of variations in water demand over 24 hours. The pumping into the Recycle Water service reservoir should be at a constant flow rate, and withdrawal shall be as per fluctuating water demand. Minimum storage/service must be provided, considering balancing of inflows and outflows. The Storage/service Reservoir shall have sufficient staging height to ensure a defined minimum terminal pressure of 17 to 21 m. The Recycle Water Service Reservoir shall be aesthetically designed by a qualified architect along with MITL branding to the satisfaction of the Employer's Engineer.

The contractor scope shall include surge analysis for the complete Recycle Water distribution network and the contractor shall provide surge protection equipment wherever necessary as per the approved design.

The scope of work shall include but not be limited to the following:

- e) Detailed design of the Recycle water distribution system and service connections
- f) Submission of design calculations, plans, 2D models and drawings
- g) Preparation of L section
- h) Construction of a Recycle Water Network as per the approved design and plans
- i) Supply and installation of Flow meters, Level sensors, Pressure sensors, and Valves as per the approved design.
- j) Supply and installation of Smart water meters to consumers of all types.
- k) Supply, Construction, Installation, Testing, Commissioning and O&M of the Recycle Water Supply System. The contractor has to manage the Recycle Water supply distribution network such that the distribution losses should not exceed 5%. The measurement shall be with reference to the flowmeter at the inlet of the Recycled Water Service Reservoir and the Inlet at the consumer meter.

The contractor shall design and construct the Recycle Water supply system on a continuous running basis, along with the installation of valves, scour valves, air release valves, thrust blocks etc. as required. All valves shall be electrically actuated except scour and air release valves.

The Contractor shall furnish all required tools, plant, instruments, materials including water, electricity, labour, consumables, etc., any and everything necessary for the construction of the works, whether or not such items are specifically stated elsewhere in this document.

The system shall be designed as a closed loop system for efficient operations and shall be designed taking the concept of a District Metering Area (DMA) with each DMA being isolated with valves and flow measured with a full-bore electromagnetic flow meter to each DMA.

In general, this work shall include designing, providing, laying, jointing and testing all pipes and specials/fittings, DI/MS (CM lined internally) pipe and specials/fittings, inlet connection, Valves, etc.

SI	Description of Item	Minimum Requirement
2	Recycle Water Transmission Line for Phase 1, Phase 2 and Phase 3	DI K9
3	Recycle Water Distribution Network	
a	HDPE Pipe sizes PE-100 PN-10	110 mm to 280 mm
b	DI Pipe sizes K-9	300 mm and above
c	Sluice Valves	Motorized actuator
d	Air Release Valves	Automatic
e	Scour Valve	Manual
4	Recycle Water Management System (web-based and app-based)	Recycle Water Management system to be integrated with its respective SCADA. The contractor shall be responsible for coordination related to the interfacing with the ICCC system (by others). Any control system under the contractor's scope shall be fed with power from UPS, supplied by the contractor. A separate operation room of 50 sq.m to be provided.
5	District Metering Area (DMA)	Maximum Area of 200 acres.
6	Flow Meters (all types)	Battery-operated electromagnetic type/power operated with min 8 hours UPS backup having integration with Recycle Water management system. Each flow meter shall have appropriate RTU-compatible GSM and OFC connectivity with respective SCADA (by contractor) for control and monitoring. However, Contractor has to ensure its interface with ICCC (by others) for monitoring only through their utility SCADA.
7	Service Water Connection	Minimum 32 mm
8	Service Water Meters	Battery-operated, Ultrasonic with 2 GSM SIMs/IoT enabled and compatible with the Recycle Water Management System.
9	Landscaping Water Tapping Points	Tapping points with valves shall be provided connection to the irrigation system for avenue plantation and landscaping as per the recycle water

SI	Description of Item	Minimum Requirement
		distribution system duly approved by the Employer's engineer.

2.3 Crossing of Transmission Lines and Distribution Network over Small River and Nallah

Suitable pipe bridges will be provided at the locations where the proposed transmission main will cross rivers/ streams. The bottom level of the pipe will be kept above the maximum water level in the water course. Final Locations of the crossing shall be verified on-site and design to be done by the contractor.

At a river where there is a road crossing (bridge/viaduct) for vehicles or passengers, the span supports for the pipeline shall match with the supports of the bridge/ viaduct. For other culvert, small river and nallah crossings, the pipe bridges shall be designed with a maximum span of 5m. The pipe supports of the pipe bridge shall be designed and constructed in accordance with approved standards. The final detailed arrangements shall be designed by the Contractor and approved by the Engineer prior to work.

Complete concrete encasement shall be provided to the pipe in cases of road crossings and nalla crossings Concrete used for this shall be of the M15 type. Before placing concrete, the pipes shall be supported near each joint with a padding of compressive material on a pre-cast concrete block. Concrete shall not be placed until the pipes have been joined, inspected, and passed hydraulic testing.

The concrete shall be placed to ensure full contact with the pipe barrel throughout its length. Necessary reinforcement steel shall be provided as per the approved design and site conditions. The concrete shall be made discontinuous at flexible pipe joints by a diaphragm of fibre board or other compressible material of at least 20 mm thickness extending for the full area of the surround. The concrete encasement shall cover the pipeline on all sides by a minimum of 100 mm on each side.

A specific geotechnical investigation shall be performed by the contractor for each proposed crossing to evaluate potential 100-year flood scour depths of the waterway at the ultimate development of the drainage basin. The final detailed arrangements shall be designed by the Contractor and approved by the Engineer prior to work.

2.4 Distribution Network

The distribution network shall be designed for a continuous pressurised water supply. Hazen-William's formula will be used for the calculation of velocities and head losses. The water distribution network shall be mostly a closed network system so that uniform pressure is maintained at the ferrule connection for each consumer. The Hazen-Williams formula is expressed as under:

$$S = hf / L = 10.67 [(Q / C)^{1.85}] [1 / (d^{4.87})]$$

Where,

S : Hydraulic slope

- hf : head loss in meters (water) over the length of pipe
L : length of pipe in meters
Q : volumetric flow rate, m³/s (cubic meters per second)
C : pipe roughness coefficient
d : inside pipe diameter, m (meters)

Following considerations shall be taken into account while designing the network:

Minimum velocity = 0.6 m/s

Maximum velocity = 3.0 m/s

2.5 SCADA/ Automation

The contractor is to ensure the compatibility and seamless transmission of the data from the Recycle Water Management System to the Integrated Command and Control System to be installed by the Master ICT System Integrator.

The butterfly valves for all pipelines shall have electrically operated actuators with appropriate RTU-compatible GSM and OFC connectivity with respective SCADA (by contractor) for control and monitoring.

However, Contractor has to ensure its interface with ICCC (by others) through their utility SCADA for monitoring only.

The contractor shall be responsible for coordination related to the interfacing with the ICCC system (by others).

Any control system under the contractor's scope shall be fed with power from UPS, to be supplied by the contractor.

2.6 Excavation Depth

All water supply pipes shall be laid below ground with a minimum clear cover of 1.2m above the crown of the pipes. No cover less than the above is acceptable.

The contractor also needs to check and design anchoring arrangements to mitigate the uplift of pipes due to the water table in the project area.

2.7 Residual Pressure

The recycle water supply distribution system shall be designed to achieve a minimum residual pressure of 17 m to 21m at each service connection.

2.8 Laying

The pipes shall be lowered into the trench by means of suitable pulley blocks, sheer legs chains ropes etc. In no case, the pipes shall be rolled and dropped into the trench. One end of each rope may be tied to a wooden or steel peg driven into the ground and the other end held by men which when slowly released will lower the pipe into the trench. After lowering, the pipes shall be arranged so that the spigot of one pipe is carefully centred into the socket of the next pipe, and pushed to the full distance that it can go.

The pipeline shall be laid to the levels required. Specials shall also be laid in their proper position.

Where so directed, the pipes and specials may be laid on masonry or concrete pillars. The pipe laid on the level ground shall be laid with a socket facing the direction of the flow of water.

The pipes shall rest continuously on the bottom of the trench. The pipes shall not rest on lumps of earth or on the joints. Four-meter-long wooden templates may be used to check the level of the bed. Clearance of approximately 100 mm in depth and width equal to the length of the collar plus 30mm on both sides shall be provided at the joint, which shall be refilled from the sides after the joint is made.

In unstable soils, such as soft soils and dry lumpy soils, it shall be checked whether the soils can support the pipelines, and if required, suitable special foundation shall be provided.

Some clayey soils (for example, black cotton soil) are drastically affected by extremes of saturation and dryness. In changing from saturated to a dry condition, these soils are subjected to extraordinary shrinkage, which is usually seen in the form of wide and deep cracks in the earth's surface and may result in damage to underground structures, including pipe materials. The clay forms a tight gripping bond with the pipe, subjecting it to excessive stresses as the clay shrinks. It is recommended that in such cases an envelope of a minimum of 100 mm of tamped sand shall be made around the pipeline to avoid any bonding.

In places where rock is encountered, a cushion of fine earth or sand shall be provided for a depth of 150 mm by excavating extra depth of the trench, if necessary, and the pipes laid over the cushion. Where the gradient of the bed slopes is more than 30 degrees it may be necessary to anchor a few pipes against sliding downwards.

2.9 Bedding

The class of bedding shall be designed considering the required external loading conditions, geotechnical requirements such as subsoil and bearing capacity of soil encountered in the respective water line, type, class and material of pipe used for the laying purposes as per the CPHEEO manual. Fine sand bedding 200mm thick shall be provided for HDPE Pipes.

Where DI pipes are to be bedded directly on the bottom of the trench, it is to be trimmed and levelled to permit even bedding of the pipeline and should be free from all extraneous matter which may damage the pipe or the pipe coating. Additional excavation shall be made at the joints of the pipes so that the water main is supported along its entire length. Where excavation is through rocks or boulders, the pipeline shall be bedded on concrete bedding or on at least 150 mm of fine-grained material, or other means are used to protect the pipe and its coating.

For MS pipes the bottom of the trench shall be properly trimmed to permit even bedding for the pipeline. For pipes larger than 1200 mm in diameter in earth and murrum, the curvature of the bottom of the trench shall match with the curvature of the pipe as far as possible, subtending an angle of about 120° at the centre of the pipe. Where rock or

boulders are encountered, the trench shall be trimmed to a depth of at least 100 mm below the level at which the bottom of the barrel of the pipe is to be laid and filled to a like depth with lean cement concrete or with the non-compressible material like sand of adequate depth to give the curved seating.

2.10 Thrust Blocks

Thrust blocks are required to transfer the resulting hydraulic thrust from the fitting of the pipe onto a larger load-bearing soil section.

Thrust blocks shall be installed wherever there is a change in the direction/size of the pipeline or the pressure line diagram, or when the pipeline ends at a dead end. If necessary, thrust blocks shall be constructed at valves also.

Thrust blocks shall be constructed considering the pipe size, water pressure, type of fitting, gravity component when laid on slopes and the type of soil.

When a fitting is used to make a vertical bend, it shall be anchored to a concrete thrust block designed to have enough weight to resist the upward and outward thrust. Similarly at joints, deflected in the vertical plane, it shall be ensured that the weight of the pipe, the water in the pipe and the weight of the soil over the pipe provide resistance to upward movement. If it is not enough, ballast or concrete shall be placed around the pipe in sufficient weight to counteract the thrust.

When the line is under pressure, there is an outward thrust at each coupling. Good soil, properly tamped is usually sufficient to hold pipe from side movement. However, if soft soil conditions are encountered, it may be necessary to provide side thrust blocks or other means of anchoring. In such cases, only the pipe on each side of the deflected coupling shall be anchored without restricting the coupling.

Pipes on slopes need to be anchored only when there is a possibility of the backfill around the pipe sloping down the hill and carrying the pipe with it. Generally, for slopes up to 30 degrees, well-drained soil carefully tamped in layers of 100 mm under and over the pipe, right up to the top of the trench will not require anchoring.

2.11 Joints

A Joint is a connection between the ends of pipes in which a gasket is used to affect a seal.

Ductile Iron pipes comprise of the following joints:

- a) Socket and Spigot Push-on Joint
- b) Flanged Joint
- c) Flexible Joints and Interconnection and
- d) Restrained Joints

Push-on flexible joints shall be provided for pipe-to-pipe connection as per IS 8329. Wherever, flange joints are required e.g., at terminal points, valves, over-ground and underground pipe connections etc., welded-on flanges shall be used.

Double-chambered restrained joints need to be designed in accordance with ISO 10804:2018. The permissible angular deflection will be as declared by the manufacturer. The Performance Type Test of this Joint in line with ISO 10804/EN545 has to be established by the manufacturer by getting it witnessed by a NABCB (National Accreditation Board for Certification Bodies), or IAF (International Accreditation Forum) or EA (European Cooperation for Accreditation) accredited institution/certification agency.

2.12 Valves and Fittings

For the operation and maintenance of the transmission and distribution system minimum numbers of valves are necessary. The transmission and distribution mains shall be provided with the following appurtenances and specials as per the following criteria.

2.12.1 Sluice Valve

Resilient seated sluice valve of standard makes as per IS 14846 shall be proposed at different locations as per requirements to isolate a portion for maintenance.

2.12.2 Non-Return Valve

Non-return valves of standard make as per IS 5312 shall be proposed at different locations as per requirements to prevent any backflow.

2.12.3 Pressure Reducing Valve

Pressure-reducing valves with pressure-sustaining override shall be provided to reduce the pressure difference between the locations of the same zones.

2.12.4 Air Release Valve

Automatic air release valves with EPDM of standard make shall be proposed at suitable locations in the rising mains and distribution network to protect the line from both upsurge and down surges. The valve diameter shall be as per design requirements and guidelines.

2.12.5 Scour Valve

Scour valves of standard make shall be installed in the rising mains and distribution system at lower points in the line to drain silt and water from the line whenever required.

All the valves shall be enclosed in valve chambers with cover.

2.13 Back Filling and Tamping

Backfilling shall follow pipe installation as closely as possible to protect the pipe from falling boulders, eliminating the possibility of pipe lift due to flooding of the open trench and shifting the pipe out of line by caved-in soil.

The soil under the pipe and coupling shall be solidly tamped to provide firm and continuous support for the pipeline. Tamping shall be done either by tamping bars or by using water to consolidate the backfill materials. Minimum MDD of compacted soil shall not be less than 95%.

The initial backfill material used shall be free of large stones and dry lumps. In stony areas, the material for initial backfill can be shaved from the sides of the trenches. In bogs and marshes, the excavated material is usually little more than vegetable matter and this should not be used for bedding purposes. In such cases, gravel or crushed stone shall be hauled in.

The initial backfill shall be placed evenly in a layer of about 100 mm thick. This shall be properly consolidated, and this shall be continued till there is a cushion of at least 300 mm of cover over the pipe.

If it is desired to observe the joint or coupling during the testing of mains, they shall be left exposed. Sufficient backfill shall be placed on the pipe to resist the movement due to pressure while testing.

Balance of the backfill need not be so carefully selected as the initial material. However, care shall be taken to avoid backfilling with large stones which might damage the pipe when spaded into the trench.

Pipes in trenches on a slope shall have extra attention to make certain that the newly placed backfill will not become a blind drain in effect because until back fill becomes completely consolidated there is a tendency for ground or surface water to move along this looser soil resulting in a loss of support to the pipe. In such cases, the backfill shall be stamped with extra care and the tamping continued in 100 mm layers right up to the ground level.

2.14 Property Connections

Service pipes should be laid up to plot boundaries in the Project area and end-capped. The service pipe details are as defined below:

Table 2-1: Details of Property Connections

S.No.	Description	Value
1	Pipe and accessories	Service connections of required size as per water demand (Minimum 32mm), including supply and fixing of electrofusion saddle, clamps, rubber sheets, tapping, compression fittings etc, complete.
2	Pipe Material	HDPE
3	Number of property connections and water meters	96

2.15 Design Parameters for Distribution Network

Table 2-2: Design Parameters for Distribution Network

S.No.	Design Parameter	Value
a)	Minimum residual pressure at service connection (unless otherwise specified by Employer/ Employer's Engineer)	17 m to 21m
b)	Peak factor	For Residential as per CPHEEO; For industrial to be decided as per industrial process. (minimum 1.5)

S.No.	Design Parameter	Value
c)	Losses as Unaccounted for water (UFW) to be considered for designing	15% losses (in transmission and distribution combined)
d)	Bedding	Bedding for HDPE / DI shall be as per relevant IS codes
e)	Clear cover over pipe	The water supply pipeline shall be laid with a minimum cover of 1.5m over the pipe crown
f)	Basis of supply to consumers	Continuous pressurized
g)	Maximum unit head loss in the pipe	10 m/Km
h)	Hazen William Coefficient	As per CPHEEO Manual
i)	Pipe Material	HDPE minimum 110 mm upto 280mm HDPE (PE-100); PN 10 DI-K9: Size 300mm and above

2.16 List of Standards and Specifications

Detailed specifications for the water supply system shall conform to the standards listed below.

CPHEEO Manual for Water Supply & Treatment System, 2023

SP 7 (2016): National Building Code of India, 2026

Urban and Regional Development Plans Formulation and Implementation Guidelines, 2014

SP-35: Handbook on Water Supply, Plumbing & Drainage, 1987

Manual on norms and standards for environment clearance of large construction projects, MoEF

IS 1172: Code of Basic requirements for water supply, drainage and sanitation

IS 8329: Centrifugally Cast (spun) Ductile Iron Pressure Pipes for Water, Gas and Sewage — Specification

IS 12288: Code of practice for laying of ductile iron

IS 9523: Ductile iron fittings for pressure pipes for water, gas and sewerage

IS 4984: High-Density Polyethylene Pipes for Water Supply

This page is intentionally blank.

3 Stormwater Drainage

3.1 Scope

The Scope of Work shall include:

- a) Detailed Design and plans for the stormwater drainage system
- b) Submission of design calculations, plans, 2D models and drawings
- c) Preparation of L section and construction drawings
- d) Construction of stormwater Network as per approved design and plans
- e) Testing, Commission and O & M of the System

The contractor shall design and construct the stormwater drainage system and shall furnish all required facilities, plant, equipment and materials, including water, electricity, labour, consumables, etc., any and everything necessary for the construction of the works, whether or not such items are specifically stated elsewhere in this bid. The Standards and Specifications for the Design and Construction of Stormwater Drainage Systems are given in this section.

The contractor shall make their arrangements for water and power required for the work, and nothing extra will be paid for the same.

This will be subject to the conditions that the water used by the contractor (s) shall be fit for construction purposes to the satisfaction of the Employer's Engineer. No underground water usage for construction is permitted.

Arrangement of Power for construction purposes is the contractor's responsibility.

In general, this work shall include the construction of Precast Rectangular box drains, catch basins and inter-connection infrastructure, including but not limited to pipes, gratings etc.

The precast pipe drains shall be mandatorily factory-made, fair-finished.

The major objective of stormwater drainage system design is to protect the area from flooding and efficient operation of systems during the design storm events. The drainage system is designed to collect stormwater run-off from roadway surface and right-of-way, along with runoff from plots and convey it along and through the stormwater network and discharge into a receiving body without causing adverse site impacts.

Stormwater collection systems shall be designed to provide adequate surface drainage. Surface drainage is a function of transverse and longitudinal pavement roughness, inlet spacing and inlet capacity.

The stormwater drainage system shall be designed with an integrated approach considering the relevant external catchment. Further, it shall be designed considering all the relevant parameters, including future development works. The contractor is to refer to the indicative Tender drawings for the tentative disposal point of the stormwater drain. The Outfall Location shall be verified on-site, and the design to be done by the contractor. Outlet points shall be terminated in a natural water body having adequate assimilating capacity as approved by the Engineer-in-charge.

The discharge design facilities for stormwater collection and conveyance systems include consideration of stormwater quantity and quality. The general considerations in the design of stormwater drains shall be:

- i. Drains shall be designed for appropriate design frequency/ 5 year return period depending on the importance of the development and economic considerations.
- ii. Drains shall be planned to take into consideration the ground levels, slope of the ground, valley and ridges and also the land uses planned for urban development.
- iii. Drains shall be planned to get an adequate longitudinal slope, considering the nature of the soil and subsoil water level. Drainage of large areas can be better achieved by subdividing them into small grids to avoid a long main drain. The aim should be to get a high velocity for the dominant flow.
- iv. Efficiency in the maintenance of the drainage system is an important consideration in selecting the size, shape and location. The specification of the drain shall also aim at preventing the possibility of ingress of other extraneous materials, debris, vegetation, etc. Where grating is provided on drains, they shall be so located as to attract the attention of maintenance staff, be easy to approach, inspect and clean it.

Sl	Description of Item	Minimum Requirement
1	Return period for the design of Storm Water Drains	5 years
2	Drain Type	Precast Pipe Drain of size as per approved design
3	Catchment Area	Runoff water from plots, future roads and adjoining areas.
4	Property connections	Minimum 96 subject to the contractor's design.
5	Manhole Covers	Maximum 20 m and at junctions/bends as per approved design. The manhole cover and frame shall be Precast SFRC heavy-duty factory-made with embossed MITL logo. conforming to the IS 12592.
6	The preliminary drawings shall be prepared to ensure that stormwater runoff from all plots and catchment areas located along the existing 60 m road, as well as the plots and catchment areas associated with the proposed future road, is adequately collected and conveyed through the stormwater drainage system included within the current 60 m road execution scope. While carrying out the detailed design, the contractor shall consider the entire contributing catchment area, including existing and future development, natural ground levels, runoff characteristics, rainfall intensity, discharge points and future drainage connectivity. Accordingly, the contractor shall design the complete stormwater drainage network within the current 60 m road corridor with adequate hydraulic capacity and suitable provisions for future connections.	

3.2 Catchments

The stormwater drainage system should be planned by dividing the BIA project area into various micro drainage catchments based on the topography.

The design discharge shall be calculated as per the Rational Method and the Roughness coefficient of the surface. Catchments shall be delineated based on topography and the location of outfalls. The EPC contractor shall carry out detailed investigations to explore the feasibility of utilising the existing water bodies as the final outfall of stormwater for the Priority -I BIA project area.

The EPC contractor shall delineate the entire project area and consider all relevant parameters for designing a stormwater drainage network.

3.3 Hydraulic & Hydrological analysis for estimation of the Highest Flood Level

The contractor has to delineate the associated catchment of the stream/river to analyse the data based on hydrological analysis, considering the different rainfall scenarios. The study shall be carried out based on the Govt. published papers, CWC, IS codes, IRC or Govt. Manuals.

The contractor shall arrive at the Highest Flood Level (HFL) for the area and validate the results with the details of the existing nearby culvert/bridge and the elevations from the survey data set. The above result will define the Road formation levels, cross-drainage structures and outfalls of the drainage network.

3.4 Storm Frequency/ Return Period

The components of the proposed stormwater drainage system shall be designed for the following design standards based on national and international best practices:

- Once in a 5-year event flows for stormwater drains/channels.
- Once in a 25-year event flows for culverts
- Once in a 50-year event flows for minor bridges

3.5 Rainfall Intensity

For the estimation of flood discharge, the Central Water Commission (CWC), jointly with the India Meteorological Department (IMD), RDSO, Ministry of Railways and Ministry of Surface Transport, has compiled very useful data. The entire country has been divided into 26 hydrometeorological homogeneous subzones. The project area falls under West Coast Region subzone 5(a) and (b), as per the flood estimation report.

The contractor has to develop the IDF curve before starting of design of the stormwater network and get approval on the same from the Employer Engineer. To prepare the IDF curve the contractor is required to collect/purchase authenticated AWS/ARG datasets on 1 hour duration rainfall for the last 30 years minimum, to prepare the IDF curves as cited above.

3.6 Other Design Parameters

The minimum and maximum design velocity shall be as per the guidelines of the CPHEEO manual on the Stormwater Drainage System.

3.6.1 Minimum Longitudinal Gradient

A minimum longitudinal gradient of 0.3 per cent shall be provided for satisfactory drainage as per Ref: IRC: SP: 50-2013. Steeper gradient as per site requirement shall be calculated and submitted for Employer Engineer approval.

3.6.2 Inlet Spacing

The spacing of inlets depends on the condition of the road surface size and type of inlet/Catch basin* and rainfall. They shall be provided at closer intervals near junctions and valley curves; however, maximum spacing shall not be more than 30 m. (Ref: IRC: SP:50-2013).

** Catch basin denoted as a node to reflect the drain detail like Ground level, invert level and size of drain. Purpose of inlet is to catch road surface runoff and outlet into drain.*

3.6.3 Freeboard

The freeboard is the vertical distance from the water surface of designed flow condition to the top of the channel. The importance of this factor depends on the consequence of overflow of the channel bank. Freeboard should be sufficient to prevent waves, superelevation changes, or fluctuations in water surface from overflowing the sides. The recommended value of minimum freeboard for different widths of drains is given in the table below:

Table 3-1: Minimum Free Board

S.No.	Drain Size	Free Board
1.	Up to 300 mm bed width	10 cm
2.	Beyond 300 mm & up to 900 mm bed width	15 cm
3.	Beyond 900 mm & up to 1500 mm bed width	30 cm
For larger drains, the freeboard shall be higher than 30cm depending upon the discharge		

3.7 Design Methodology

3.7.1 Rational Method

Storm runoff is that portion of the precipitation which drains over the ground surface. Estimation of such runoff is dependent on the intensity and duration of rainfall, characteristics of the tributary area and the time required for such flow to reach the drain. In the usual case of urban drainage systems, the Rational method is widely used for estimating the peak runoff rates. It is used to estimate the peak instantaneous discharge from the watershed, and it is assumed that the peak runoff rate is proportional to the peak intensity of rainfall multiplied by the contributing area. The constant of proportionality is called a 'runoff coefficient', always lesser than unity. The formula is:

$$Q = CIA/360$$

Where:

Q = flow, m³/s

C = weighted runoff coefficient

I = rainfall intensity in mm/hr

A = drainage area in hectares

The assumptions and limitations inherent in the Rational Formula are:

Runoff coefficient - The runoff coefficient incorporates a large number of variables into a single index that ranges between 0 and 1. In addition, the parameter can take on a wide range of values even for the same land use characteristics.

Rational method is simplistic in its accounting of runoff and loss processes, so must be limited to small, relatively homogenous, and simple watersheds.

It only provides a single value on the discharge hydrograph, the peak discharge. If the objective is to determine the size for an inlet or a pipe, then this single point on the discharge hydrograph is adequate.

Peak flow occurs when the entire watershed is contributing to the flow.

Rainfall intensity is the same over the entire drainage area.

The frequency of the computed peak flow is the same as that of the rainfall intensity.

The coefficient of runoff is the same for all storms of all recurrence probabilities.

3.7.2 Synthetic Unit Hydrograph Method

This method is based on unit hydrograph principle and used when catchment area is greater than 25 sq km. Central Water Commission (CWC) has published Flood Estimation Report for different zone for India. The project alignment falls in the West Coast Region subzone 5(a) and (b).

Synthetic Unit graph parameters are computed using the following equations

t_p	$0.258[L L_c / (S)^{0.5}]^{(0.49)}$
q_p	$1.017/[t_p]^{(-0.520)}$
W_{50}	$2.396*[q_p]^{(-1.08)}$
W_{75}	$1.427*[q_p]^{(-1.08)}$
W_{R50}	$0.75*[q_p]^{(-1.25)}$
WR_{75}	$0.557*[q_p]^{(-1.12)}$
TB	$7.193*[(t_p)^{(-0.53)}]7.621*[(t_p)^{(0.623)}]$
QP	$q_p * A$
T_m	$t_p + t_r/2$

Where,

T = Time from the center of Unit rainfall duration to the peak of Unit Hydrograph

q_p = Peak discharge of hydrograph per unit area

W_{50} = Width of U. G. measured at 50% maximum discharge ordinate

W_{75} = Width of U. G. measured at 75% maximum discharge ordinate

W_{R50} = Width of the rising side of U. G. measured at 50% of maximum discharge ordinate

WR_{75} = Width of the rising side of U. G. measured at 75% of maximum discharge

ordinate

- TB = Base width of Unit Hydrograph
QP = Peak discharge of Unit Hydrograph
Tm = Time from the start of rise to the peak of unit hydrograph in hours
tr = Unit rainfall duration adopted in a specific study in hours

3.7.3 Time of concentration

The storm duration chosen for design is equal to the time of concentration. Maximum discharge in drainage system occurs when the entire catchment is contributing to the flow. The time of concentration, (tc) is the time required for a given drop of water from the most remote part of watershed to reach the point of interest. Detail analysis of Tc for each catchment need to done by the EPC contractor to arrive at a particular time(Hrs) to calculate travel time of flow for each catchment.

The concentration time depends on

- a) the distance from the critical point to the structure; and
- b) the average velocity of flow.

IRC:SP:13-2004 suggested following relationship for time of concentration.

$$t_{c,c} = [0.87 \times (L^3/H)]^{0.385}$$

Where, $t_{c,c}$ = the concentration time in hours

L = the distance from critical point to the structure in km

H = the fall in level from the critical point to the structure in meter

3.7.4 Critical Intensity

The critical intensity for a catchment is that maximum intensity which can occur in a time interval equal to the concentration time t_c of the catchment during the severest storm (in the region) of a given frequency I_c , Since each catchment has its own t_c , it will have its own I_c

$$I_c = I_o (2 / (t_c + 1))$$

(Ref: IRC -SP 13:2004)

3.7.5 Runoff Coefficient

The runoff coefficient, C, in Equation is a function of the ground cover and a host of other hydrologic abstractions. Where watershed is not homogeneous but is characterized by dispersed areas that can be characterized by different runoff coefficients, a weighted runoff coefficient should be determined. It relates the estimated peak discharge to a theoretical maximum of 100 percent runoff. Typical values for C are given in table below. If the basin contains varying amounts of different land cover or other abstractions, a composite coefficient can be calculated through area weighing using Equation below:

$$\text{Weighted C} = \Sigma(Cx \cdot Ax) / A_{\text{total}}$$

Where:

x = Subscript designating values for incremental areas with consistent land cover

The runoff coefficient for the project area development based on the proposed land use pattern are shown in below table.

Table 3-2: Runoff Coefficients for Rational Formula (refer IRC SP 50 Table-6.1)

Land use	Runoff Coefficient	Definition
Industrial	0.75	Industrial
Residential	0.35	Residential areas
Commercial, Mixed Use, PSP (Public and Semi-Public)	0.8	Densely built areas
Parks & Open Spaces (including green buffers, ecological parks)	0.20	Green area (Sandy)
Transportation (Roads, Transport & Logistics)	0.9	Pavement (Bitumen or Concrete)

3.7.6 Hydraulics

Drainage network to be designed as per relevant guidelines of CPHEEO manual, IRC codes, IS Codes as described in above sections.

The size of the drains shall be determined using Manning's formula.

The Manning's equation is given below:

$$Q = \left(AR^{2/3} S^{1/2} \right) / n$$

Where,

Q = Discharge capacity of the drain in m³/s

n = Manning's roughness coefficient

A = Flow area in m²

R = A/P = Hydraulic radius in m

P = Wetted perimeter in m

S = Channel slope

3.8 Covered Lined Drain for Storm Water System

A separate dedicated collection and conveyance network is proposed for the collection and safe disposal of stormwater. The system shall comprise storm water interception & diversion facilities and a network of rectangular RCC drains. The drains shall be completely covered at the top.

Collection & conveyance network shall be planned considering natural topography and planned grade levels. The network shall be designed on the assumption that although silting might occur at times of low flow, however, it should be flushed out during peak flows.

3.9 Drain Size, Depth and Type

Precast RCC pipe Drain is proposed at the edge of the carriageway on both sides of the road. The sizes of stormwater drains shall be designed as per relevant IS codes and finalised in consultation with the Employer's Engineer during the Detailed Engineering Stage.

The stormwater runoff shall be intercepted through catch basins which eventually convey it to drain through a connecting pipe. Catch basins shall be equipped with CI gratings and their spacing shall as per relevant IRC code for efficient drainage. However, the contractor can propose alternate materials & type of grated inlets to stormwater with the approval of the Employer Engineer.

3.10 List of Standards and Specifications

The design and construction of storm water drainage network and the outfalls shall conform to design requirements and construction specifications set out in the following Indian Standards.

- a) IS - 456 Code of practice for Plain & Reinforced concrete.
- b) IRC SP-50-2013 - Guidelines on Urban Drainage
- c) IS - 458 Pre-cast Concrete Pipes (with and without reinforcement);
- d) IRC SP-42-2014- Guidelines on Road Drainage
- e) C.P.W.D. specifications (Govt. of India) with all latest amendments issued from time to time.
- f) CPHEEO Manual for Storm Water Drainage Systems -2019 - MoUD, Gol
- g) SP 35:1987 - Hand book of Water Supply and Drainage, Bureau of Indian Standards.
- h) Manual on artificial recharge of ground water by Central groundwater Board Ministry of Water-Resources Government of India.
- i) Rain water harvesting and conservation Manual by consultancy services organization CPWD, New Delhi, India;
- j) IS14333:1994 High Density Polyethylene Pipes for Sewerage-Specification
- k) IS 4515:2002 Stone Pitched Lining
- l) IS 3873:1993 Laying of Cement Concrete /Stone Slab Lining on Canal
- m) IS 7740: 1985 Code Of Practice For Construction And Maintenance Of Road Gullies
- n) IS 5961: 1970, Specification of Cast Iron Grating for Drainage Purpose.

This page is intentionally left blank

4 Industrial Wastewater and Domestic Sewage Collection System

The domestic sewerage network will collect the domestic sewage from the residential, commercial, institutional and amenities plots and convey it to the Sewage Treatment Plant (STP) located within the project area. The industrial sewer network will collect the effluent/wastewater from the industrial plots and convey it to the Common Effluent Treatment Plant (CETP) located within the project area.

The domestic sewerage and industrial effluent network shall be designed in such a fashion as to minimise any intermediate pumping requirement, but in unavoidable circumstances, intermediate sewage/effluent pumping stations (ISPS/IEPS) may be provided at places, if required.

The domestic sewerage network and industrial sewer network will be two independent networks and shall be designed as gravity systems. The network shall be designed to cater for the peak flows, with peak factors, as applicable.

The networks shall be planned considering natural topography and the proposed grade levels. The treated effluent generated from the STP and CETP will be recycled and reused completely within the project area, complying with the environmental clearance (EC) conditions.

The contractor's scope of work shall include designing, providing, supplying, lowering/ laying and jointing of pipes, including excavation, backfilling, bedding, etc, for the collection & conveyance of the domestic sewage and industrial wastewater/effluent, up to the STP and CETP.

The scope of services includes the supply of water for hydraulic testing and carrying out hydraulic tests for networks and manholes.

The scope for manholes includes design and construction of manholes, drop manholes and scrapper manholes as per the type design in RCC M-25, necessary coping in RCC, fixing GRP encapsulated Galvanized Steel Steps or Rungs, providing Precast SFRC heavy-duty factory-made with embossed MITL logo Manhole frames and covers over manholes etc. complete, including all civil works like excavation, backfilling, PCC, RCC works etc.

4.1 Scope

The Scope of Work shall include:

- a) Detailed Design, and plans for the independent systems for domestic sewerage & industrial wastewater/effluent collection & conveyance network
- b) Detailed design of intermediate sewage pumping stations (as applicable)
- c) Submission of design calculations, plans, 2D models and drawings
- d) Preparation of L section of domestic sewerage & industrial effluent/wastewater collection network and construction drawings for all components of the proposed domestic sewerage & industrial effluent system

- e) Construction of independent domestic sewerage & industrial effluent collection & conveyance network as per the approved design and plans
- f) Construction, supply, and installation of intermediate sewage & industrial effluent pumping stations, rising mains complete with all accessories, valves etc.
- g) Supply and installation of meters for online monitoring of the quantity of effluent from individual industrial plots.
- h) Installation, Erection, Testing, Commissioning and O&M of the complete domestic sewerage & industrial effluent system. The contractor shall be solely responsible for ensuring that the effluent collection system is free from any egress of water outside the system. The maintenance of all the devices, equipment, instruments, software systems etc including the cost of spares, batteries, subscription charges for SIM cards and annual maintenance, if any shall be borne by the contractor during the entire tenure of the contract for Operation and Maintenance.

4.2 Design Details for Industrial Wastewater and Domestic Sewage Collection System

The following parameters shall be followed for the design of the Industrial Wastewater Collection System and the Domestic Sewage Collection system :

Table 4-1: Design parameters of domestic sewerage & industrial effluent system

S.No.	Description	Value
1	Pipe Diameter	As per design but ID not less than 200 mm dia
2	Sewer Pipe Material along the Road	DWC pipe from 200mm to 500 mm and RCC NP3 pipe for sizes above 500mm
3	Encasing Pipe Material for Road Crossing	RCC NP4
4	Plot Connections	75 Nos. of Industrial & 21 Nos. of Residential and Commercial with a Diameter of the pipe 160mm
5	Flow meters	-
6	Intermediate Sewage Pumping Station	As per the contractor's design
7	Sewerage Management System (web-based and app-based)	-

Table 4-2: Design parameters of Manholes


SI	Description	Value
1	Type	Precast (as per approved design)
2	Material of Construction	Minimum RCC M25 with bituminous paint on the outer surfaces of Manholes and epoxy paint on the inner surface.
3	Distance	Not more than @ 30 m c/c and at Junctions, Bend, change of alignment and additional manhole for plot connection, as required.
4	Manhole Covers	Precast SFRC heavy-duty factory-made with embossed MITL logo.
5	Depth of Manholes	Minimum depth – 1.2 m

		Maximum depth – 6 m
6	Manhole Flushing System	To be considered using recycle water as per the approved design.
7	The preliminary drawings shall be prepared to ensure that the wastewater generated from all industrial and residential plots located along the existing 60 m road, as well as from the plots proposed along the future road, is adequately collected and conveyed through the sewerage network included within the current 60 m road execution scope. While carrying out the detailed design, the contractor shall consider the present and projected future wastewater generation from the entire contributing area, including industrial effluent and domestic sewage, ground levels, flow quantities, peak flow factors, invert levels, pumping requirements, treatment facilities, discharge points and future network connectivity. The contractor shall design the complete sewerage network within the current 60 m road corridor with adequate hydraulic capacity and suitable provisions for future connections. Industrial effluent and domestic sewage shall be collected through separate networks unless their combined conveyance is specifically approved by the competent authority and complies with applicable environmental and statutory requirements.	

4.3 Background

The domestic sewerage network will collect the sewage from the residential, commercial, institutional and amenities plots and convey it to the sewage treatment plant (STP) located within the project area or outside as indicated on the Drawings. The industrial effluent network will collect the wastewater from the industrial plots and convey it to the common effluent treatment plant (CETP) located within the project area or outside the project area as indicated on the Drawings.

The implementation limit of these two systems will be from the service connection point outside the plot boundaries to the inlet points of the intermediate sewage pumping station if any and/or directly to STP premises by gravity system to the best possible extent. The design and construction of the property chamber for connection are in the scope of the contractor.






Figure 4-1: Domestic Sewerage Effluent Collection & Conveyance Network

Figure 4-1: Industrial Effluent and Domestic Sewerage Collection & Conveyance Network

4.4 Estimated Generation of Industrial Wastewater and Domestic Sewage

Table 4-3: Domestic Sewage / Industrial Effluent Generation

Land use	Without infiltration (MLD)	With infiltration (MLD)	Remarks
Pharma industries	2.24	2.46	Industries sewer
Industries	15.58	17.14	Industries sewer
Residential	26.47	29.11	Domestic sewer
Commercial	0.48	0.52	Domestic sewer
Amenities	3.11	3.42	Domestic sewer
Sub Total	47.88	52.66	

4.5 Rate of Infiltration

Infiltration into the domestic sewerage & industrial effluent system occurs through defective sewers, manholes, etc. The rate of infiltration into sewers also depends upon the groundwater table and the permeability of the surrounding soil. Though strict quality control and good workmanship would ensure minimum infiltration, however as the system condition deteriorates with age, the possibility of infiltration increases.

For the hydraulic design of sewers, an allowance for infiltration shall not be more than 10% of the total domestic sewage / industrial effluent flow per day.

4.6 Design Period

Industrial Wastewater and Domestic Sewage collection, conveyance, treatment & disposal projects are designed to meet the future requirements of a stipulated design period. This period, with regard to certain components of the project, depends on their useful life or the facility for carrying out extensions whenever required, so that expenditure far ahead of its utilisation is avoided and capital expenditure incurred on the project does not remain idle due to underutilization of these facilities. For the purpose of designing such systems, a 30-year project period is recommended. The design period normally considered for various components is as under:

Pipeline and it's appurtenances	:	30 years
Pumping Mains	:	30 years
Mechanical and Electrical Components	:	15 years

4.7 Peak Factor

As far as the design of the Industrial Wastewater and Domestic Sewage network is concerned, it is the hourly variation in consumption of water that matters. The fluctuations in consumption are accounted for, by considering the peak rate of consumption as rate of flow in the design of network. The flow in sewers varies considerably from hour to hour and also seasonally, but for the purposes of hydraulic design it is the estimated peak flow that is adopted. The peak factor or the ratio of maximum to average flows, depends upon contributory population & industrial processing. In general, the following values shall be adopted as suggested in the CPHEEO manual and as tabulated below:

Table 4-4: Peak Factors for Contributory Population for Per Capita Sewage Flow

Contributory Population	Peak Factor
For population less than 20,000	3.00

For population range of 20,000 to 50,000	2.50
For population range of 50,000 to 750,000	2.25
For population above 750,000	2.00

Since the variability of flow in industrial sewers is not as high as domestic sewer and depends on the batch production, the contractor after discussing with the Employer/PMNC shall consider the same in designing the system. However, for the design of effluent network, a minimum peak factor of 1.5 shall be considered

4.8 Sewage Pumping Stations

The Industrial Wastewater and Domestic Sewage system shall be planned and designed in such a fashion that no intermediate pumping is required. However, the same is to be ascertained during the detailed design of the respective system by the contractor. The scope and specifications given in this section are applicable to intermediate pumping stations for both domestic sewerage and industrial effluent systems.

For sewer depths higher than 6m, the increase in depth of cut leads to an increase in the cost of excavation. Lower depth of sewers will increase the number of ISPS. Considering the soil strata, high groundwater table (1.5m from ground during monsoon) and depth of sewer & industrial effluent network, efforts to be taken to minimize the depth of pumping stations up to 6m. The design of SPS/ISPS shall be based on contributing flow, area availability, maximum depth of sewer, high ground water table, etc. Open excavation shall be used for construction of pumping stations with side slope of 1V: 1.5H up to 3.0m depth and with side slope of 1V: 2H for deeper excavation, along with 1m wide berms at every 4.0m.

Method of open excavation as defined above can be adopted up to a depth of 6 to 7.5 m below ground in open/unrestricted areas. Whereas, for deeper excavation or excavation in restricted areas, sheet piling can be adopted since excavation area will be more due to side slope and berms.

Intermediate Sewage Pumping stations are included in the scope of contract and laying of sewer pipeline up to Inlet of Intermediate Pumping station and from outlet of common delivery pipe (rising main) to the nearest Manhole and further network will be under the present scope of services. The pump houses shall be of adequate size to house the pumps of required capacity and other allied electrical and mechanical equipment, also designing and providing all PLC/SCADA/Automation requirements for required components.

In case intermediate pumping is required, the intermediate sewage pumping station shall be designed with given below specifications:

Pipe Material for Rising Main shall be DI pipe K 9 as per (IS 8329) with sulphate resistant cement internal CM lining.

The wet well shall be designed as per sub clause 4.6.6. of CPHEEO manual on Sewerage & Sewage Treatment Systems. However, minimum diameter of the wet well shall be 1.5 m.

The Pumps shall be of submersible type with open impeller. Detailed specification of the pumps shall be referred from general mechanical specifications provided in the tender document.

For average dry weather flow upto 3 MLD, at least one mechanical screen shall be provided and for average dry weather flow of 3 MLD or more, at least two mechanical screens with 100% standby shall be provided. In case, it is not possible to accommodate the screens within the wet well, a separate screen chamber before the wet well shall be provided.

The Pump house shall be in RCC construction of required grade as called in the tender.

The pumping station shall be designed with odour control system.

Pumping system configuration, capacity of pumps, type of operation (continuous/VFD/intermittent) shall be selected such that

- a) No of start / stops of pumps at any inlet flow condition (whether lean/avg/peak) for constant flow pumps should not be more than 6 times /hr.
- b) 100% or more standby at all conditions of pumping flow
- c) If VFD is selected, then turn down operating condition should not be below 30 – 50% of original speed.
- d) Suitable control/throttling system to be considered if continuous flow pumps are selected.
- e) Suitable Lifting equipment for pumps and screens to be provided.

Suitable level measuring transmitters for pump well/ screen chamber to be provided.

Sewage / Industrial effluent Pumping system details shall be referred from the relevant section and General Mechanical Specification of this specification.

Pumping Arrangement and Duties

Pump shall comply with CPHEEO manual or standard Manual.

The Contractor shall include for the design, supply, installation, testing and commissioning of all pumps listed in the sections below for the stormwater pumping station.

Piping inside pumping station shall be of ductile iron (DI). The contractor shall propose suitable size pumps and provide all necessary hydraulic calculation for Client/Engineer approval. The pumping installation shall be provided with the following pump duties and arrangement, to give the stated pumping rate. The head given below is indicative and only for guidance and the same shall be calculated by the contractor based on the shop drawings for the pumping station and connected pumping mains. The pumps shall be of constant speed drive.

Stormwater Pumps:

Duty (each pump) : 257 cum/hrs
Head : *17.5 m
Quantity : 3 Nos
Arrangement : 2 Duty and 1 Standby
Type : Sewage non-clog submersible pump

(* The pump final TDH will be as per (a) Site condition, (b) Final forcemain pipe route & profile, (c) Equipment selection, and (d) Final shop drawing).

The Contractor shall submit pump and system performance curves based on the above which are to include details of power absorbed and efficiency. The Contractor to submit also with the pumps all testing reports, including but not limited to, Hydrostatic, Performance, Vibration. etc.

The defined duty point for the pumps shall be based on the wet well bottom water level. The Contractor shall ensure that the pumps can operate satisfactorily over the full range of operating conditions.

Pumps total capacity shall be equal to or exceed the incoming sewerwater peak flow rate to the pumping station.

The flow and head data given are nominal values. The Contractor shall carry out his own calculations to establish the final values of flow, head and shall submit his calculations to the Engineer for review prior to ordering any of the pump equipment.

The closed valve head shall be a minimum of 110% of the duty head.

The Contractor shall examine the design of the civil structure and either confirms it is acceptable for his proposed equipment or advises the engineer of all changes he requires.

The wet well is of a circular geometry. The pumps are configured to cover the full range of flow with sewage non-clog submersible pumps, with Duty/Standby arrangement. The pumping station comprises of DN 250 mm DI pipe discharge branch includes DN 250 DI non return valve (NRV), 250 mm DI Dismantling Joint and DN 250 DI electrically operated Gate Valve, common header, tees etc.

4.9 Property Connections

Service pipes for the property connections should be laid up to plot boundaries in the project area & end capped. The service pipe details are as defined below:

Table 4-5: Tentative Details of Property Connections

S.No.	Description	Value
1	Pipe Diameter	Not less than 200 mm OD.
2	Pipe Material	DWC dia upto 500 mm and RCC dia above 500 mm

3	Total number of domestic sewerage property connections	21
4	Total number of industrial property connections	75

4.10 Coefficient of Roughness

The coefficient of roughness is based on the type of pipe material proposed for the sewage collection & conveyance. As per guidelines of the CPHEEO manual on Sewerage & Sewage Treatment Systems, the coefficient of roughness “n” for DWC pipe shall be considered as 0.010.

4.11 Design Capacity of Sewers

Sewers shall be designed to carry estimated peak flows generated in the design year and would be designed 80% full at ultimate peak flow. This is to ensure proper ventilation and prevent septicity of sewage. No sewer pipe shall run at any time more than 80% full.

4.12 Minimum and Maximum Velocity in Sewer

Considering typical values of particle size and specific gravity, minimum partial flow velocities are considered at present peak flows and at design peak flows. The maximum velocity shall be considered in order to prevent scouring.

A velocity of 0.6 m/s would be required to transport sand particles of 0.09 mm size with a specific gravity of 2.65. Thus, the sewers are designed on the assumption that although silting might occur at minimum flow, it would be flushed out during peak flows. Erosion of sewers is caused by sand and other gritty material in the sewer and also by excessive velocity. Velocity in a sewer is recommended not to exceed 3 m/s.

Table 4-6: Maximum and Minimum Velocity in Sewer

S.No.	Criteria	Velocity (m/s)
1	Minimum velocity at initial peak flow	0.6
2	Minimum velocity at ultimate peak flow	0.8
3	Maximum velocity	3.0

4.13 Slope in Industrial Wastewater and Domestic Sewage Collection System

The minimum slopes that shall be considered for the design of the network are as in the table below:

Table 4-7: Minimum Slopes

S.No.	Sewer Size (Mm)	Minimum Slope (1 In)
1	200	250
2	250	360
3	300	450
4	375	670
5	450	830
6	>=525	1000

4.14 Bedding

For HDPE pipes bedding shall be designed taking into account the required external loading conditions, geotechnical requirements such as subsoil and bearing capacity of soil encountered in the respective sewer line, type, class and material of pipe used for the laying purposes as per CPHEEO manual on Sewerage & Sewage Treatment Systems and IS 783.

Fine sand bedding 200mm thick shall be provided for HDPE Pipes.

The contractor also needs to check and design the anchoring arrangement to mitigate the uplift of pipes due to the high-water table in the project area.

4.15 Manhole Size, Depth, and Type

The channels in Manholes at junctions and bends shall be smooth with gradual transitions to avoid turbulence and deposition of solids. Manholes are usually constructed directly over the line of the sewer. They are circular, rectangular or square in shape. Manholes should be of such size that will allow necessary cleaning and inspection. As per IS-4111: 1986 “Circular type Manholes are much stronger than rectangular and arch type Manholes and thus these are favoured over rectangular as well as arch type Manholes”. Therefore, circular Manholes shall be proposed on all sewer lines for all depths starting from 0.9m. The diameter of the Manhole varies with the change in depth of the Manhole. GRP-encapsulated GI Rungs shall be provided for entry into Manholes.

The scope for this item includes providing and constructing precast RCC circular manholes, Drop manholes and flushing manholes in accordance with the CPHEEO manual on Sewerage & Sewage Treatment Systems and IS 4111 part 1 and 2. The contractor has to minimize the number of drop manholes; however, if required drop manholes shall be provided in line with the recommendation of the CPHEEO manual on Sewerage & Sewage Treatment Systems. Flushing manholes shall be connected with a recycle network system with all necessary arrangements. The contractor's scope also includes the provision of flushing water in case of the non-availability on recycle water during the initial years.

Table 4-8: Manhole Sizing

Range of Depths, m	Maximum Dia Up to	Manhole Size
above 0.90 m and up to 1.65 m	500 mm	900 mm dia.
above 1.65 m and up to 2.30 m	600 mm	1200 mm dia.
above 2.30 m and up to 9.0 m	900 mm	1500 mm dia.
above 9.0 m and up to 14.0 m	1200 mm	1800 mm dia.

4.16 Spacing of Manholes

As per IS – 4111: 1986, For inspection, cleaning and testing of sewers, manholes should be built at every change of alignment, gradient or diameter, at the head of all sewers and branches and at every junction. This shall be kept in mind while designing the system.

The sewer shall be in a straight line between two manholes.

The maximum distance between service manholes should not be more than 30 m.

Manhole spacing is limited to 30m for sewers having service connections.

4.17 Cover Frame

As per IS-4111: 1986, the size of manhole covers should be such that there should be clear opening of not less than 560 mm diameter for manholes exceeding 0.9 m depth.

The manhole cover and frame shall be Precast SFRC heavy-duty factory-made with an embossed MITL logo conforming to the IS 12592.

Table 4-9: Manhole Cover Details

Manhole Type	Load withstanding capacity	Suitable Locations
M.D (Medium Duty)	10.00 MT	Footpaths and Cycle Track
E.H.D (Extra Heavy Duty)	35.00 MT	Carriage way for all roads.

4.18 Crossing of Sewer lines over Small River and Nallah

Suitable pipe bridges will be provided at the locations where the proposed transmission main/distribution main will cross river/ streams. The bottom level of the pipe will be kept above the maximum water level in the water course. Final Locations of crossing shall be verified on site and design to be done by EPC contractor.

At river where there is road crossing (bridge/ viaducts) for vehicles or passengers, the span, supports for the pipeline shall match with the supports of the bridge/ viaduct. For other culvert, small river and nallah crossings, the pipe bridges shall be designed with maximum span of 5m. The pipe supports of the pipe bridge shall be designed and constructed in accordance with approved standards. The final detailed arrangements shall be designed by the Contractor and approved by the Engineer prior to work.

Complete concrete encasement shall be provided to the pipe in cases of road crossings and nalla crossings Concrete used for this shall be of the M25 type. Before placing concrete, the pipes shall be supported near each joint with a padding of compressive material on a pre-cast concrete block. Concrete shall not be placed until the pipes have been joined, inspected and passed hydraulic testing.

The concrete shall be placed to ensure full contact with the pipe barrel throughout its length. Necessary reinforcement steel shall be provided as per the approved design and site conditions. The concrete shall be made discontinuous at flexible pipe joints by a diaphragm of fibre board or other compressible material of at least 20 mm thickness extending for the full area of the surround. The concrete encasement shall cover the pipeline on all sides by a minimum of 100 mm on each side.

A specific geotechnical investigation shall be performed by the contractor for each proposed crossing to evaluate potential 100-year flood scour depths of the waterway at the ultimate development of the drainage basin. The final detailed arrangements shall be designed by the Contractor and approved by the Engineer prior to work.

However, Gravity sewers, if possible, shall be converted to pumped sewer lines by a low lift dedicated pumping station before the crossing discharging into the gravity section after crossing the watercourse; this will help in keeping the pumped sewer visible to the

eye or close to the ground at all times. The EPC contractor has to design & decide as per site conditions for all crossing at water bodies.

4.19 SCADA/ Automation

The contractor needs to coordinate with the Master ICT System Integrator (separate contract) for interfacing between the SCADA system of STP and intermediate sewage pump stations (ISPS).

4.20 List of Applicable Codes and Standards

Detailed specifications for the water supply system have been presented in section 12.8. Key standards have been listed below.

CPHEEO Manual for Sewerage and Sewage Treatment, 2013

SP 7 (2005): National Building Code of India, 2026

Urban and Regional Development Plans Formulation and Implementation Guidelines, 2014

SP-35: Handbook on Water Supply, Plumbing & Drainage, 1987